

Комплектность

A	1
B	3

1. **ОТКЛ.** (Release) - Initial state of the handle.

2. Use a screwdriver to lift the handle.

3. Remove the handle from the device.

4. Insert the handle into the device. **N°3 ø45** (3 pieces, diameter 45).

5. Tighten the screws (B) to secure the handle.

6. Final adjustment of the handle position.

7. The handle is now in the closed position.

8. The handle is ready for use. **max n°3 ø5...8** (Maximum 3 cables, diameter 5...8).